



Metropolitan Water Board.



*New River Head.
Rosebery Avenue.
London. E. C. 1.*

26th November, 1963.

ANY REPLY SHOULD BE ADDRESSED TO THE

Distribution Engineer
(Supplies).

AND THE FOLLOWING REFERENCE QUOTED:—

LVHD/TS.926.

Your Ref. AC/JS.

Dear Sir,

"Shetack" Socket Formers and Reducing Tools for Copper Pipe.

It has been brought to my notice that the Board still hold a number of socket formers and reducing tools in their Testing Station submitted by you some time ago.

It is understood that a verbal approval has been given to a representative, but in order to regularise the matter, and for the purposes of record, I have to inform you that no objection will be raised to joints made on copper tube up to 2" in diameter by these tools when the directions are followed closely by the operator.

This letter does not constitute an endorsement of the product for sales or advertising purposes and is not to be used as such.

Will you please arrange for the disposal of the fittings.

Yours faithfully,

A. A. Wood

Distribution Engineer.

The Secretary,
The "Shetack" Tool Works Ltd.,
Tunstall Road,
Brixton,
S.W.9.